

INTERNATIONAL INDIAN SCHOOL - JEDDAH

UNDER THE PATRONAGE OF EMBASSY OF INDIA, RIYADH
AND AFFILIATED TO CENTRAL BOARD OF SECONDARY EDUCATION, NEW DELHI - INDIA
MEMBER, COUNCIL OF C.B.S.E. SCHOOL IN GULF
AFFILIATION NO. 5730001, SCHOOL CODE - 90072
MINISTRY OF EDUCATION - K.S.A - LICENCE NO. 045 / J, C.C.No. 136593
P.O. Box 14861 JEDDAH 21434, SAUDI ARABIA
Boys' Section - Tel. +966 12 6751536 / 6711934 / 6712097
Girls' Section - Tel. +966 12 6721607 / 6718345
Girls' Section I & II - Tel. +966 12 6737752, KG-SECTION - Tel. +966 12 6747737



المدرسة الهندية العالمية - جدة

تحت رعاية سفارة الهند، الرياض
وتابعة للمجلس المركزي للتعليم الثانوي، نيودلهي - الهند
عضو مجلس C.B.S.E. مدرسة في الخليج
الانتماء رقم. ٥٧٣٠٠٠١ رمز المدرسة - ٩٠٠٧٢
وزارة التعليم - ترخيص رقم - ج/٠٤٥، رقم العضوية: ١٣٦٥٩٣
ص.ب: ١٤٨٦١ جدة ٢١٤٣٤، المملكة العربية السعودية
ت: قسم البنين: +٩٦٦ ١٢ ٦٧٥١٥٣٦ / ٦٧١٢٠٩٧ / ٦٧١١٩٣٤
ت: قسم البنات: +٩٦٦ ١٢ ٦٧٢١٦٠٧ / ٦٧١٨٣٤٥
ت: قسم البنات للصف الأول والثاني: +٩٦٦ ١٢ ٦٧٣٧٧٥٢، روضة وتمهيدي - +٩٦٦ ١٢ ٦٧٤٧٧٣٧

IISJED/ESTATE/22-23/1

Date:29/06/2022

TENDER NOTICE Request for Quotation

International Indian School Jeddah Invites E- Quotation for the supply of Window and Split AC for the school as per following details :

SL	PARTICULARS	QUANTITY REQUIRED (Each)	COOLING CAPACITY
1	Split AC	40	2.5 TON
2	Window AC	20	2 TON

Technical Specification for Split Air Conditioners (ACs)

1.0 Scope of Work:

- 1.1 The supplier/ vendor will quote the price for the unit excluding installation charges. Installation will be done by the school.
- 1.2 Supply of O&M manual

2.0 **Qualification Criteria of Bidder:** Only original equipment manufacturers or their authorized dealers/distributors/representatives are eligible for submitting the bid against this tender.

3.0 **Delivery: Packing & Transportation:** Proper packing and safe delivery within 15 days from the date of issue of PO at International Indian School without any carriage charges.

4.0 Special Requirements:

All manufacturing defect will be resolved under warranty.

5.0 **Acceptance:** Acceptance shall be based on the testing, performance demonstration and satisfactory working of ACs.

6.0 Feature of the required Split Air Conditioner

#	Parameter	Unit	Value
1.	Preferred Makes	EA	Zamil , Carrier & O General
2.	Tonnage	Ton	2.5 Ton ,30000 BTU/h

1 of 2



3.	Star Rating	Stars	≥ 3
4.	Rated Cooling Capacity	Watts	8.352KW
5.	Rated EER	W/W	8.30 BTUh/W
6.	Power Supply	V/Hz/Ph	230-1-60
7.	Air Flow Volume - Indoor	CMH	≥ 1100
8.	Noise Level - Indoor	dB(A)	≤ 50
9.	Operation		LCD Remote
10.	Compressor Type		Scroll / Sealed
11.	Refrigerant		Eco-friendly R410
12.	Filter Type		Anti-Dust/Catalyst or equivalent
13.	Anti-Corrosive Coating		Blue Fin/Gold Fin or equivalent


TECHNICAL SPECIFICATION OF WINDOW AIR CONDITIONER

1. **Technical Details:** Each unit shall consist of following:

SL NO	Description	Rating of Window Air Conditioner
1	Nominal Cooling capacity in TR (Btu/Hr.)	2 TON , 24000 Btu/h
2	Type of compressor	Large
3	Refrigerant	R-22
4	No. of fan speed cooling	As per manufacturer's standard
5	Power supply	230V AC±10%, 1 ph. 50 Hz.
6	Type	Washable
7	Air ventilation & Voltage Overload protection	Required

NB: E Quotation may kindly be submitted on tenders@iisjed.org OR sealed Quotation may be submitted to the office of IIS Jeddah at Boys section (Al Rehab) within 15 days from the date of issue of this notice.




(Principal)